

Laboratory approved by the Ministry for the Interior

JO of February 10, 2007

OFFICIAL REPORT OF CLASSIFICATION OF FIRE PERFORMANCE

Of A MATERIAL ENVISAGED IN ARTICLE 5

DECREE OF November 21, 2002

N° CM - 21 - P - 117

Page 1

et 1 annexe de 4 pages.

Valid 5 years as from jeudi 23 septembre 2021

Material presents by : **IBENA TEXTILWERKE GmbH**Peterskamp 20
46414 RHEDETrade mark: **9781 DECO MOLLETON**

Summary description

Kind of textile woven

Composition 100% cotton

Mass per unit area 160 g/m² - épaisseur/ thickness : 0,5 mm (donnée laboratoire FCBA)

Kind of Fire retardant ecru, bleached or piece dyed, napped on both sides, not permanently flame retardant

Color tous coloris / all colors

Nature of the test : Electrical burner test

Classification : **M1**

Observations :

Durability of the classification (Article 5 de l'annexe 2) 12 months starting from the implementation in a regulated building

Usual term Walls hung covering, sheers, curtains,...

Cleaning conditions Recommendation of Customer

Taking into account the criteria resulting from the tests annexed described in the test report N°FE 21-0286-1521

This official report attests only characteristics of the sample submitted for testing and does not prejudice similar characteristics of products. It thus does not constitute a certification of products within the meaning of the L.115-27 article of the code of the consumption and the law of June 3rd, 1994.

NOTE: The integral reproductions and by photocopy of this official report of classification are only authorized or the official report unit of classification and report of annexed test. These conclusions relate only to the resistance / reaction to fire performance of the element that is the subject of the present classification report. They do not prejudice, in any case, other performances related to its incorporation to a work "

"Not legally acceptable for any use under the pretence of the article AM 18 (Decree of March 6th, 2006) for upholstered seat"

Champs-sur-Marne, le jeudi 7 octobre 2021

Technicien d'essais du Laboratoire Feu

Responsable Technique du laboratoire Feu
du Pôle Ameublement

Siège social
10 rue Galilée
77420 Champs-sur-Marne
Tél + 33 (0)1 72 84 97 84
www.fcba.fr
Siret 775 680 903 00132
APE 7219 Z
Code TVA CEE : FR 14 775 680 903



Bilel HAMILA



Only the french version remains valide
Institut technologique FCBA : Forêt, Cellulose, Bois - construction, Ameublement



Clotilde ETIEMVRE