

Laboratory approved by the Ministry for the Interior

JO of February 10, 2007

OFFICIAL REPORT OF CLASSIFICATION OF FIRE PERFORMANCE

Of A MATERIAL ENVISAGED IN ARTICLE 5

DECREE OF November 21, 2002

N° CM - 20 - P - 022

et 1 annexe de 4 pages.

Page 1

Valid 5 years as from mardi 4 février 2020

Material presents by : **IBENA TEXTILWERKE GmbH**

Peterskamp 20

46414 RHEDE

Trade mark: **9774 SOUND ABSORBER**

Summary description

Kind of textile fabric

Composition 100% cotton

Mass per unit area 500 g/m² - épaisseur : 1,5 mm (donnée laboratoire FCBA)

Color black

Kind of Fire retardant napped on both sides, dyed, not permanently flame retardant

Nature of the test : Electrical burner test

Classification : **M1**

Observations : /

Durability of the classification (Article 5 de l'annexe 2) 12 months starting from the implementation in a regulated building

Usual term Walls hung covering, sheers, curtains,...

Cleaning conditions No cleaning

Taking into account the criteria resulting from the tests annexed described in the test report N^{FE} 20-0012-0048

This official report attests only characteristics of the sample submitted for testing and does not prejudice similar characteristics of products. It thus does not constitute a certification of products within the meaning of the L.115-27 article of the code of the consumption and the law of June 3rd, 1994.

NOTE: The integral reproductions and by photocopy of this official report of classification are only authorized or the official report unit of classification and report of annexed test. These conclusions relate only to the resistance / reaction to fire performance of the element that is the subject of the present classification report. They do not prejudice, in any case, other performances related to its incorporation to a work "

"Not legally acceptable for any use under the pretence of the article AM 18 (Decree of March 6th, 2006) for upholstered seat"

Champs-sur-Marne, le mercredi 12 février 2020

Technicienne d'essais
du Laboratoire Feu

Clotilde ETIEMVRE

Only the french version remains valid
Institut technologique FCBA : Forêt, Cellulose, Bois construction, Ameublement