



INSTITUT TECHNOLOGIQUE

INSTITUT TECHNOLOGIQUE FCBA

Fire Laboratory

10 rue Galilée - 77420 Champs-sur-Marne

Laboratory approved by the Ministry for the Interior
JO of February 10, 2007

OFFICIAL REPORT OF CLASSIFICATION OF FIRE PERFORMANCE Of A MATERIAL ENVISAGED IN ARTICLE 5 DECREE OF November 21, 2002

N° CM - 17 - P - 032

Page 1

et 1 annexe de 4 pages.

Valid 5 years as from **lundi 19 juin 2017**

Material presents by : **IBENA TEXTILWERKE GmbH**

Peterskamp 20
46414 RHEDE

Trade mark: **Article 9714 EURO MOLTON**

Summary description

Kind **Tissé**

Composition **64% coton / 36% polyester**

Mass per unit area **320g/m²**

Color **Noir**

Kind of Fire retardant **Washed and flame retardant finishing**

Nature of the test : **Electrical burner test**

Classification : **M1**

Observations : /

Durability of the classification (Article 5 de l'annexe 2) **12 months starting from the implementation in a regulated building**

Usual term **Walls hung covering, sheers, curtains,...**

Cleaning conditions **Recommendation of Customer**

Taking into account the criteria resulting from the tests annexed described in the test report **N°FE 17-0191-1103**

This official report attests only characteristics of the sample submitted for testing and does not prejudice similar characteristics of products. It thus does not constitute a certification of products within the meaning of the L.115-27 article of the code of the consumption and the law of June 3rd, 1994.

NOTE: The integral reproductions and by photocopy of this official report of classification are only authorized or the official report unit of classification and report of annexed test.


"Not legally acceptable for any use under the pretence of the article AM 18 (Decree of March 6th, 2006)"

Champs-sur-Marne, le **lundi 19 juin 2017**

Technicienne d'essais
du Laboratoire Feu

Siège social **Clotilde ETIEMVRE**
10 rue Galilée
77420 Champs-sur-Marne
Tél + 33 (0)1 72 84 97 84
www.fcba.fr
Siret 775 680 903 00132
APE 7219 Z
Code TVA CEE : FR 14 775 680 903

Only the french version remains valide



Institut technologique FCBA : Forêt, Cellulose, Bois - construction, Ameublement